

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7320-1501:142 Page 1 of 1

CATEGORY: Speakers

LISTEE: Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models EG4-S2, EG4R-S2, EG4-S7, EG4R-S7, EG4F-S7, EG4RF-S7, EG4F-S2, EG4RF-S2, EGC-S2, EGCF-S2, EGC-S7, EGCF-S7 and *EGCFR-S7 speakers. Models EG4-S2VM, EG4R-S2VM, EG4-S7VM, EG4R-S7VM, EG4F-S2VM, EG4RF-S2VM, EG4F-S7VM, EG4RF-S7VM, EGC-S2VM, EGCF-S2VM, EGC-S7VM, EGCF-S7VM, EGC-S2VMH, EGCF-S2VMH, EGC-S7VMH, EGCF-S7VMH, *EGCFR-S7VM, *EG4F-S2V1575, *EG4RF-S2V1575, *EG4F-S7V1575 and *EG4RF-S7V1575 Speaker strobes. Models EG4B and EG4RB speaker enclosure backbox. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 25 Vrms or 70 Vrms
¼ W, ½ W, 1 W, 2 W
G4 Candela: 15cd, 30cd, 75cd, 110cd
GC Candela: 15cd, 30cd, 75cd, 95cd
H Candela: 95cd, 115cd, 150cd, 177cd
*EG4F-S2V1575, *EG4RF-S2V1575, *EGF-S7V1575, *EG4RF-S7V1575: 15/75cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical & candela rating, and UL label.

APPROVAL: Listed as speakers and speaker/strobes for use with separately listed compatible fire alarm control units. Speakers with a strobe are suitable for the hearing impaired. For indoor use only. *Models EG4-S2VM, EG4R-S2VM, EG4-S7VM, EG4R-S7VM, EG4F-S2VM, EG4RF-S2VM, EG4F-S7VM, EG4RF-S7VM, EGC-S2VM, EGCF-S2VM, EGC-S7VM and EGCF-S7VM are untended to be used with models G1M-RM(CSFM Listing No. 7320-1657:201), SIGA-CC1S and SIGA-MCC1S (CSFM Listing No. 7300-1657:121) sync modules. Refer to listee's Installation Instruction Manual for details.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal.

XL: 7320-1591:211

*Rev. 06-27-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division